



State of Utah

JON M. HUNTSMAN, JR.  
Governor

GARY R. HERBERT  
Lieutenant Governor

## Department of Administrative Services

D'ARCY DIXON PIGNANELLI  
Executive Director

### Division of Facilities Construction and Management

F. KEITH STEPAN  
Director

## ADDENDUM

Date: 3 April 2006

To: Chris Rindlisbacher, Eagle Environmental, Inc.  
Pat Philabaum, Rocmont Industrial, Inc.  
Shannon Sandberg, Environmental Abatement, Inc.  
Jeff Orr, Thermal West Industrial, Inc.  
Ken Stoker, Fresh Air Environmental Solutions  
William Vasquez, PDGE

From: Robert J. Anderson, Project Manager, DFCM

Reference: Lind Lecture Hall, Asbestos Abatement & Demolition  
Weber State University

DFCM Project #: 05283810

Subject: **Addendum No. 1**

Pages:	Addendum	2 pages
	<u>Architectural Addendum</u>	<u>0 pages</u>
	Total Pages	2 pages

**Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.**

1.a.1 "REVISED" Bid Form – Attached (notes unit pricing for pipe fittings, laterals, conacles & pipe hanger saddles 4" , 6" and 8" diameter).

1.b.1 Unit pricing for pipe fittings, laterals, conacles & pipe hanger saddles on "Revised" Bid Form.

1.b.2 Unit pricing for pipe fittings, laterals, conacles & pipe hanger saddles on "Revised" Bid Form.

1.b.3 Unit pricing for pipe fittings, laterals, conacles & pipe hanger saddles on “Revised” Bid Form.

1.c.1 Schedule Change: Project to start approximately May 5<sup>th</sup>, 2006 with substantial completion on June 16<sup>th</sup>, 2006.

1.d.1 REF: Sheet DAE 100, cadaver lab Room 020 Ceiling Demo Plan: The note should read: “Remove existing ceiling, grilles & light fixtures” (the comma was inadvertently missing). The ceiling is to be remove, see Key Note #2 on sheet DAC 101.

1.e.1 REF: Sheet DAE 101, the protective cover detail A5 is required at all permanent displays. If contractor feels there is an acceptable alternate to provide the same durable covering and support of that covering, it should be noted in proposal. The protective covers are to remain in place after the completion of this contract, to continue the protection during construction.

1.f.1 REF: Sheet DAE 102, Cabinets shown in the rooms will remain in place during demolition/abatement and must be protected. The desk (noted as shelving) in Office 231B will remain in place, not to be removed.

1.g.1 REF: Sheet DEE-ALT, delete this sheet from the bid package, this work will not be required by the demolition contractor.

1.h.1 REF: Sheets DEE101, DEE101 General Demolition Notes: notes refer to an Electrical Contractor; it is required to retain a licensed electrician to secure the power feeds to the panels, prior to disconnecting circuits and removing conductors, etc., as indicated in the notes. Reference to General Contractor should be reference to WSU electrical or mechanical shops managers.

1.i.1 REF: Sheets DEE101, DEE102 Reference Notes: the reference to Mountain Alarm coordination requires that Mountain Alarm be retained to perform any work associated with fire alarm devices.

1.j.1 REF: Sheet DMH100, the ductwork shown dashed in the Mechanical Room 018 is to remain (it is shown dashed because it exists above the large duct).

1.k.1 REF: Sheet DMH101, Key Note #1: this work is to be part of the base scope, not an alternate task.

1.l.1 REF: Sheet AE 102, in rooms #225, 205,206 & 208 delete note 13, the wall base is to remain.

*End of Addendum*